

Pellston Public Schools Roofing Project

Addendum # 1

April 23, 2025

NOTE: Bid date remains April 30, 2025.

- Dimensions on roof plans and details are for reference only. Bidders are responsible to field verify all measurements.
- The roof deck on the elementary gym is an exposed Tectum deck. Contractors are to use caution as not to penetrate the underside of the Tectum deck with the roof fasteners.
- All shingle underlayments are to be approved and warrantied by the shingle manufacturer for a complete systems warranty.
- Work is to start after June 13, 2025 and be completed and clean up by August 29, 2025